


GOVT OF ASSAM
OFFICE OF THE DIRECTOR
ASSAM ROAD RESEARCH & TRAINING INSTITUTE, PWRD, FATASHIL AMBARI, GUWAHATI-25.



PHYSICAL TEST OF REINFORCEMENT BARS

Name of The Work : Test report of reinforcement bars

Name of Division/Organization: Maithan Steel & Power Limited, 9, A.J.C Bose Road , Ideal Centre, 6th floor , Kolkata.
 Reference No. : **Your letter No :-Nil** **Date-24/07/18** **Job No. 2139.**

Sl. No.	Dia. of the bars (mm)	Tensile Strength In(N/mm ²)	Elongation (%)	Mass/Imeter In (gm)	Bend & Re-bend test	Remarks
1	2	3	4	5	6	7
1	8	718.55	15.00	412.60	Passed	(1)Tensile Strength required = 660.00 N/mm ² (min) & 2)Elongation =10.00%(min)
2	10	692.99	16.00	614.30	Passed	
3	12	707.96	16.67	898.40	Passed	
4	16	705.97	15.00	1590.00	Passed	

Note:1) The test results relates only the samples which were supplied by the party concerned.
 2)Brand Name :-Maithan Fe-600 TMT .


 8/12/18
 Research Assistant
 ARR&TI, PWRD
 Fatashil, Ambari, Guwahati-25.


 Asstt. Engineer
 ARR&TI, PWRD,
 Fatashil, Ambari, Guwahati-25.

8/12/18

 Dy. Director
 ARR&TI, PWRD
 Fatashil Ambari, Guwahati-25.